



NOTES

1. Gate Valves shall be A.W.W.A.\* approved.
2. check valves shall be Hersey Model EDC or Mueller Model A-2131-6 or approved equal, Underwriters Laboratory (UL) and Factory Mutual (FM) approved.
3. See Standard detail No. 13 for Meter setting requirements.

\* UL and FM approved if requested by customer.

WESTCHESTER JOINT WATER WORKS			
STANDARD DETAIL			
DETECTOR CHECK VALVE			
NOT TO SCALE	DATE	BY	DETAIL
	4/6/87	W.ABBES	14