



SIZE		FORD
METER	SERVICE	CUSTOM SETTER
1½"	1½"	VVF 66-36 X 13¼" WITHOUT BYPASS
2"	2"	VVF 77-36 X 17¼" WITHOUT BYPASS

**GENERAL NOTES**

1. CURB STOP AND BOX SHALL BE LOCATED BETWEEN CURB AND SIDEWALK. WHERE THERE ARE NO SIDEWALKS, CURB STOP AND BOX SHALL BE LOCATED BETWEEN CURB AND PROPERTY LINE. WHERE THERE ARE NO CURBS, CURB STOP AND BOX SHALL BE LOCATED BETWEEN EDGE OF PAVEMENT AND PROPERTY LINE.
2. CURB STOP AND BOX SHOULD NOT BE LOCATED IN A PAVED DRIVEWAY OR PARKING AREA.
3. SERVICE LINE SHALL BE OF TYPE K COPPER WHERE SHOWN. SIZE SHALL BE SAME AS METER SIZE.
4. METER PIT SHALL BE LOCATED BETWEEN THE CURB STOP AND BOX AND THE PROPERTY LINE. WHERE THERE ARE SIDEWALKS, METER PIT SHALL BE LOCATED BETWEEN THE SIDEWALK AND THE PROPERTY LINE. METER PIT SHALL NOT BE INSTALLED IN DRIVEWAYS, PARKING LOTS OR IN ANY OTHER AREA WHERE IT COULD BE SUBJECT TO TRAFFIC LOADING. WHERE A METER PIT MUST BE LOCATED IN A PAVED AREA, WATER WORKS APPROVAL OF THE LOCATION MUST BE OBTAINED AND PROTECTIVE MEASURES SHALL BE TAKEN TO PREVENT PARKING AND TRAVELLING OF VEHICLES OVER THE PIT.
5. METER PIT SHALL NOT BE CUT DOWN IN SIZE.
6. METER PIT, COVER AND SETTER ARE THE PROPERTY OF THE CUSTOMER, WHO SHALL MAINTAIN SAME IN SATISFACTORY CONDITION AS REQUIRED BY THE WATER WORKS.

**REGULATIONS REGARDING METER ACCESS AND PROTECTION**

1. CUSTOMER IS RESPONSIBLE FOR PROTECTION OF METER, AND WILL BE BILLED ALL COSTS RELATING TO DAMAGE OF THE METER CAUSED BY FREEZING, BACKFLOW OF HOT WATER OR OTHER PHYSICAL ABUSE.
2. CUSTOMER IS RESPONSIBLE FOR KEEPING PIT IN A DRY, SAFE, AND SANITARY CONDITION, TO GRADE, AND ACCESSIBLE AT ALL TIMES TO THE WATER WORKS. NO FENCE OR ENCLOSURE SHALL BE BUILT AROUND METER PIT THAT WOULD IMPEDE ACCESS TO PIT BY WATER WORKS.
3. CUSTOMER SHALL NOT REMOVE OR TAMPER WITH METER NOR SHALL HE REMOVE, DAMAGE OR DEFACE ANY SEALS PLACED ON METERS OR VALVES BY WATER WORKS.
4. THE WATER WORKS MAY TERMINATE SERVICE WHERE COMPLIANCE WITH ACCESS REQUIREMENTS IS NOT OBTAINED, OR WHERE TAMPERING WITH THE METER AND/OR SEALS, OR REPEATED DAMAGE TO THE METER FOR ANY REASON HAS OCCURRED.

**WESTCHESTER JOINT WATER WORKS**

**STANDARD DETAIL NO. 12**

BY	DATE	SCALE	FILE NO.	DETAIL
RW	1-10-83	NONE		12

**METER PIT FOR 1½" AND 2" METERS**